

DISTRICT WATER TESTING LABORATORY, GURDASPUR

District Water Testing Laboratory, Jewanwal Babri, Gurdaspur
dwtlgsp1@gmail.com

To,

Rosedale School
vill- Chuhur Chack, P.O : N.M Singh (Distt Gurdaspur)

No.: DWTLGSP/2324/00001 Dated : 05/04/2023

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. RS-04-2023/24 Dated: 03/04/2023

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 03/04/2023. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Gurdaspur

D/A : Test Report



**Authorized Signatory
For, District Water Testing Laboratory,
Gurdaspur**



**Principal
Rosedale School
Chuhur Chak, Gurdaspur (Pb.)**



**BHAI JETHA JI EDUCATIONAL SOCIETY
Vill. Chuhur Chak, P.O. Naushera Majja Singh
Teh. & Distt. Gurdaspur (Punjab)**

DISTRICT WATER TESTING LABORATORY, GURDASPUR

District Water Testing Laboratory, Jewanwal Babri, Gurdaspur
dwtlgsp1@gmail.com



TC-10019

TEST REPORT

Name & Address of Customer : Rosedale School vill- Chuhur Chack, P.O : N.M Singh (Distt Gurdaspur)	Customer Reference No.	No : RS-04-2023/24 Dated : 03/04/2023
	Sample Submitted by	Rannit kaur
	Date of Sample Receipt	03/04/2023
	Analysis Starting Date	03/04/2023
	Analysis completion Date	05/04/2023

Discipline : Chemical Testing		Group: Water	
ULR No.:	TC100192300000090F	Sample Type :	Water
Test Report No.:	DWTLGSP/2324/00001	Date of Issue :	05/04/2023
Registration no.:	DWTLGSP/REG2324/00001	Condition of Sample :	Unsealed
Collection Point:	Private Submersible	Quantity/Type of Bottle:	1000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Rosedale School Vill-Chuhur Chack / NA
Village :	Chuhur Chak	Habitation :	Chuhur Chak
Block:	Dhariwal	District :	Gurdaspur
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.4	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-1993) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 1984) (RA 2017)
5	TDS	310	500	2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
7	Alkalinity	132	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
8	Hardness	160	200	600	mg/l	IS 3025 (Part 21- 2019) EDTA Method
9	Calcium	32.06	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium	19.44	30	100	mg/l	APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method
11	Chloride	9.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method


This Report is issued under the following terms & Condition :


1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%



Mr. Pankaj Kumar
Quality Manager
Authorized Signatory
For, District Water Testing Laboratory,
Gurdaspur

End of the Test Report


Rannit Kaur
Principal
Rosedale School
Chuhur Chak, Gurdaspur (Pb.)


Bhai Jetha Ji
President
BHAI JETHA JI EDUCATIONAL SOCIETY
Vill. Chuhur Chak, P.O. Naushera Majra Singh
Teh. & Distt. Gurdaspur (Punjab)

SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE

No. 226

Date: 24/05/2023

It is certified that an inspection team headed by Chetanjit Singh

D.E.

inspected the Rosedale School Village
Chuhar Chak, P.O. Naushehra Majja Singh, District Gurdaspur on 24/5/23
and found that Rosedale School Village Chuhar Chak, P.O. Naushehra Majja Singh,
District Gurdaspur has safe drinking water facilities for the students and members of
staff of the institution and is maintaining the hygienic sanitation condition in the
school & the campus as per the norms prescribed by the central / State/ U.T Govt.

The above valid for a period of one year w.e.f 1/4/23 to 31/3/24

Anil Kumar
Sub Divisional Engineer,
Water Supply & Sanitation,
Sub Division Dhariwal.

To

Rosedale School
Village Chuhar Chak, P.O.
Naushehra Majja Singh, District Gurdaspur.

Anil Kumar
Sub Divisional Engineer,
Water Supply & Sanitation,
Sub Division, Dhariwal

Ramneet Kaur
Principal
Rosedale School
Chuhar Chak, Gurdaspur (Pb.)

H. Jetha Ji
President
BHAI JETHA JI EDUCATIONAL SOCIETY
Vill. Chuhar Chak, P.O. Naushehra Majja Singh
Teh. & Distt. Gurdaspur (Punjab)